

The latest in **FIRE PREVENTION**



CHULA VISTA FIRE DEPARTMENT

Bulletin No. 2011-02 • October 25, 2011

ONE- AND TWO-FAMILY DWELLING WATER METER SIZE

To Whom It May Concern:

This official correspondence sets forth the current water meter requirements for one- and two-family dwellings that are required to be protected throughout by an approved automatic fire sprinkler system (2010 California Residential Code, Section, R313.2). The minimum size water meter required for the National Fire Protection Association (NFPA) 13D (Dwelling) Sprinkler Systems in the City of Chula Vista is one inch (1"). If you have any questions regarding this matter, please contact me at 1-619-691-5029.

Thanks you for your cooperation in making our community fire safe.



JUSTIN GIPSON, FIRE MARSHAL

Fire Department • 276 Fourth Avenue • Building 300, Suite B-143 • Chula Vista, CA 91910
(619) 691-5029 • fax (619) 691-5204 • www.chulavistaca.gov/goto/fireprevention